

# 先端医学棟地下水槽リスト

番号	水槽名	平面(m <sup>2</sup> )	側面(m <sup>2</sup> )	水槽深さ(m)	水槽水位(m)	水槽自体の 容量(m <sup>3</sup> )	溜まり容積(m <sup>3</sup> )	ポンプ仕様		
								機器番号	能力	台数
1	高温排水槽	11.6	6.0	2.3	0.40	26.57	4.6	A-PD-3	50φ × 200L/min × 6m	2
2	汚水槽	22.7	16.1	2.3	0.80	52.14	18.1	A-PD-1	80φ × 150L/min × 6m	2
3	雑排水槽	34.9	19.4	2.3	0.75	80.36	26.2	A-PD-2	50φ × 250L/min × 6m	2
4	高温排水冷却槽	11.4	11.9	2.3	0.80	26.20	9.1			
5	中和原水槽	22.9	5.7	2.3	0.29	52.60	6.5	P1-1	40φ × 130L/min × 4m	1
								P1-2	40φ × 130L/min × 4m	1
6	高温排水原水槽	11.5	10.3	2.3	0.69	26.52	8.0	P01	50φ × 50L/min × 14m	1
								P02	50φ × 50L/min × 14m	1
7	感染中継槽	22.8	2.6	2.3	0.13	52.53	3.0	P2-1	32φ × 40L/min × 20.5m	1
								P2-2	32φ × 40L/min × 20.5m	1
8	感染原水槽	35.2	5.9	2.3	0.23	81.05	8.0	P4-1	50φ × 50L/min × 10m	1
								P4-2	50φ × 50L/min × 10m	1
								P1-1	50φ × 50L/min × 10m	1
								P1-2	50φ × 50L/min × 10m	1
9	感染原水槽	59.6	16.0	2.3	0.50	137.15	29.8			
10	雑排水槽	12.2	9.6	2.3	0.65	28.04	7.9	A-PD-7	65φ × 300L/min × 7m	2
11	汚水槽	10.6	8.6	2.3	0.60	24.47	6.4	A-PD-6	80φ × 150L/min × 7m	2
12	雑排水槽	18.7	13.1	2.3	0.65	42.99	12.1	A-PD-5	65φ × 500L/min × 9m	2
13	汚水槽	18.7	11.1	2.3	0.55	42.90	10.3	A-PD-4	80φ × 300L/min × 9m	2